



| OPUCN APPROVED METER SOCKET TYPES | | | |
|-----------------------------------|---------------|-------|---------------|
| | MANUFACTURER | | |
| | MICROELECTRIC | HYDEL | CUTLER-HAMMER |
| 2 POSITION | BD2-V/BD2-VH | H22R | 2K2 |
| 3 POSITION | BD3-V/BD3-VH | H23R | 3K2 |

NOTES:

1. TOLERANCE ON DIMENSIONS +/- 10%.
2. THE METER SOCKET MUST BE MOUNTED ON AN OUTSIDE WALL AT A LOCATION APPROVED BY OPUCN METER DEPARTMENT TO CO-ORDINATE WITH DISTRIBUTION ON THE STREET.
3. ELECTRICAL SERVICE SHALL MEET ALL ESA INSPECTION STANDARDS AND SHALL BE INSPECTED BY ESA BEFORE CONNECTION TO THE DISTRIBUTION SYSTEM.
4. DISCONNECT SWITCH MUST BE ADJACENT TO THE METER BASE
5. REFER TO "OPUCN APPROVED METER SOCKET TYPES" FOR SOCKET REQUIREMENTS.
6. AN APPROVED AND PROPERTY LABELED SINGLE LINE DIAGRAM OF THE CONNECTION SHALL BE POSTED AT THE DISCONNECTION SWITCH AND AT THE INVERTER.
7. MINIMUM 1m CLEARANCE IS REQUIRED BETWEEN THE GAS METER/RELIEF VENT AND THE ELECTRIC METER SOCKET.

| CONVERSION TABLE | |
|------------------|--------------------|
| METRIC | IMPERIAL (APPROX.) |
| 1m | 3'-3" |
| 1.75m | 5'-8" |
| 3m | 10'-0" |

